

**INFORMATION ONLY**

**E3632A-05**

**S E R V I C E**

**N O T E**

Supersedes:  
NONE

## **E3632A DC Power Supply**

**Serial Numbers: ALL**

**Output Regulation Symptom (UNREG) at 102Vac to 107Vac**

**Parts Required:**

P/N	Description	Qty.
-----	-------------	------

NONE

### **ADMINISTRATIVE INFORMATION**

SERVICE NOTE CLASSIFICATION:

**INFORMATION ONLY**

AUTHOR: TL

PRODUCT LINE: WC

ADDITIONAL INFORMATION:

© AGILENT TECHNOLOGIES, INC. 2011  
PRINTED IN U.S.A.

October 19, 2011

Rev. 18




**Agilent Technologies**

Page 1 of 3

**Situation:**

The E3632A has intermittent output regulation issue (UNREG) if the power supply output voltage changes from 0V to 15.7V-16.4V when using the following programming sequence at AC input power from 102Vac to 107Vac

```
*RST  
VOLT:RANG P30V  
VOLT 0  
CURR 1  
OUTPUT ON  
// WAIT 10; set delay for 10s  
VOLT 16
```




UNREG measurement observed on E3632A

**Solution/Action:**

To prevent this voltage UNREG symptom, Agilent recommends the user to execute the “VOLT 15” command before the target VOLT command as shown below.

```
*RST  
VOLT:RANG P30V  
VOLT 0  
CURR 1  
OUTPUT ON  
// WAIT 10; set delay for 10s  
VOLT 15  
VOLT 16
```

By adding the VOLT 15, the UNREG will be eliminated.



UNREG measurement eliminated on E3632A by adding “VOLT 15” command